

ADDENDUM NO. 1

**CITY OF EAST RIDGE, TENNESSEE
MECHANICAL EQUIPMENT PLATFORM**

The following changes shall be made to the DRAWINGS (prepared by Thompson Engineering dated September 13, 2017):

I. DRAWINGS

- A. **Drawing S100, General Notes.** DELETE Note 8.8 and REPLACE with the following note:
"SEE CONCRETE MIX DESIGN FOR CLASS A CONCRETE IN SPECIFICATION 03 30 00"
- B. **Drawing S100, General Notes.** DELETE the table entitled "CAST-IN-PLACE CONCRETE MIX SCHEDULE" in its entirety and REPLACE with the following "TABLE A1-1".

TABLE A1-1 CAST-IN-PLACE CONCRETE MIX SCHEDULE							
Application	Strength (PSI)	Min. Cement Content (sacks/cu.yd)	Max. Water-to- Cement Ratio (pound/pound)	Air Content	Stone Gradation	Ratio of Coarse to Fine Aggregate (by weight)	Slump (inches)
FOOTINGS	4,000	6.5	0.49	4.5% to 5.5%	# 67	1.0 to 2.0	2 to 4

NOTE: REFER TO SPECIFICATION SECTION 03 30 00, CAST-IN-PLACE CONCRETE, FOR ADDITIONAL INFORMATION ON CLASS A CONCRETE MIX DESIGN REQUIREMENTS

- C. **Drawing S100, General Notes.** DELETE Notes 5.1 through 5.7 and REPLACE with following note: "5.1 REFER TO SPECIFICATION SECTION 01 33 23 FOR SHOP DRAWINGS AND SUBMITTALS PROCEDURES"