



CTI Engineers, Inc.
 112 Durwood Road, Suite A
 Knoxville, TN 379342
 Phone 865.246.2750
 Fax 865.246.2755
 www.ctiengr.com

LETTER OF TRANSMITTAL

TO: Tech Coat, Inc
 K2 Industrial Services
 CIP
 Cleveland Utilities
 Associated General Contractors
 Builders Exchange of Tennessee
 CMD Planroom
 Dodge Data & Analytics

Todd Jones Toddjones@techcoat.net
 Rodney Hartgraves rodneyhartgraves@k2industrial.com
 Keith Mabry keith@cipaint.com

Jon Sparkman jsparkmand@clevelandutilities.com
 Cathy Stone cathy@agceten.org
reporter@bxtn.org
docprocessing@cmdgroup.com
dodge.docs@construction.com

FROM: John King, P.E., Senior Project Manager

DATE: May 15, 2020

PROJ. NO.: K20004

SUBJECT: Addendum No. 1
 Cleveland Utilities, Cleveland, TN
 FY20 CFP Facility Painting Project, W2876X

PAGES: 2 pages follow

<p>PLEASE RESPOND</p> <p>→ → → →</p>	<p>TO CONFIRM RECEIPT OF THIS ADDENDUM NO. 1 PLEASE SIGN AND EMAIL TO CTI</p> <p>jgonzalez@ctiengr.com</p>
	Company _____
	Signature _____
	Title _____
	Date _____

ADDENDUM NO. 1

**CONTRACT DOCUMENTS AND SPECIFICATIONS
FOR THE
FY20 CFP FACILITY PAINTING PROJECT, W2876X**

The following changes shall be made to the Contract Documents, Specifications, and Drawings:

I. SPECIFICATIONS

A. Section 09 91 00 – Painting

1. Page 09 91 00-4. ADD the following subparagraph to Paragraph 1.6:

“D. Paint sample taken from piping gallery wall and tested in February 2020, indicates the paint is not considered “lead-based”. Paints that contain lead quantities more than the 0.50 percent (5,000 µg/g) limit are considered “lead-based paint” by EPA. Extensive testing for lead paint in other areas and on other surfaces was not performed. Contractor may perform testing as he deems appropriate; to verify lead content; and to price their bid accordingly. No additional costs shall be awarded based on Contractor’s findings prior to or after bid award. The Contractor shall provide all safeguards relative to lead paint removal and environmental and personnel protection.

II. General Information

1. The following page depicts the paint sample results.

Date: May 15, 2020

CTI Engineers, Inc.
/s/ John King, P.E.
Senior Project Manager



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Lead Paint Chip Analysis Report

Report Number: 20-02-01538

Client: CTI Engineers Inc.
 112 Durwood Rd., Ste. A
 Knoxville, TN 37922

Received Date: 02/11/2020
 Analyzed Date: 02/14/2020
 Reported Date: 02/14/2020

Project/Test Address: CU CFP Wall Coating; Cleveland, TN 37320
 Collection Date: 02/06/2020

Client Number:
 44-6753

Fax Number:
 865-246-2755

Laboratory Results

Lab Sample Number	Client Sample Number	Collection Location	Pb (ug/g) ppm	% Pb by Wt.	Narrative ID
20-02-01538-001	1	CFP WALLS	200	0.020	

Preparation Method: ASTM E-1979-17
 Analysis Method: EPA SW846 7000B

Reviewed By Authorized Signatory: Melissa Kanode

Missy Kanode
 QA/QC Clerk

The HUD lead guidelines for lead paint chips are 0.50% by Weight, 5000 ppm, or 1.0 mg/cm². The Reporting Limit (RL) for samples prepared by ASTM E-1979-17 is 10.0 ug Total Pb. The RL for samples prepared by EPA SW846 3050B is 25.0 ug Total Pb. Paint chip area and results are calculated based on area measurements determined by the client. All internal quality control requirements associated with this batch were met, unless otherwise noted.

The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Results represent the analysis of samples submitted by the client. Sample location, description, area, etc., was provided by the client. Results reported above in mg/cm³ are calculated based on area supplied by client. This report shall not be reproduced except in full, without the written consent of the Environmental Hazards Service, L.L.C.

ELLAP Accreditation through AIHA-LAP, LLC (100420), NY ELAP #11714.

LEGEND Pb= lead ug = microgram ppm = parts per million
 ug/g = micrograms per gram Wt. = weight