

ADDENDUM ONE (1)

**FIRST UTILITY DISTRICT OF HAWKINS COUNTY
CHURCH HILL, TENNESSEE**

GRAVELLY VALLEY ROAD WATER LINE EXTENSION

BID DATE: October 27, 2020
BID TIME: 2:00 P.M., Local Time
ADDENDUM DATE: October 21, 2020

This Addendum is issued to make certain additions, deletions, revisions, clarifications and/or alterations to the Contract Documents, Specifications, Drawings, and other requirements for the subject project. Each Bidder should acknowledge receipt of this Addendum on the Bid form; however, failure to do so does not relieve the Bidder from the requirements contained herein.

I. SPECIFICATIONS:

- A. **Section 33 12 23, Water Booster Station.** Page 33 12 23-1, Paragraph 1.2.B. Delete first sentence and replace with "The system shall be hydrostatically tested at the factor prior to delivery." Delete second sentence of the same paragraph in its entirety.
- B. **Section 33 12 23, Water Booster Station.** Page 33 12 23-2, Paragraphs 2.1.A and 2.1.B. Add the word "duplex" before the word "packaged" in the first sentence of both paragraphs.
- C. **Section 33 12 23, Water Booster Station.** Page 33 12 23-4, Paragraph 2.5, "START/STOP PRESSURE SWITCH." Delete this paragraph in its entirety.
- D. **Section 33 12 23, Water Booster Station.** Page 33 12 23-5, Paragraph 2.7.A. Replace the words "Control cabinet" with the words "Pump station" at the beginning of the third sentence. Delete items 3 and 4 of the same paragraph in their entirety.
- E. **Section 33 34 00, Polyvinyl Chloride Pipe for Pressure Applications.** Page 33 34 00-3, Paragraph 2.1.B.1. Delete first sentence and replace with "Water mains shall meet ASTM D2241, Class 200, SDR 21 with push-on joints."

END OF ADDENDUM

October 21, 2020

CTI ENGINEERS, INC.
/s/ David L. Jones, P.E.