

ADDENDUM TWO (2)

**FIRST UTILITY DISTRICT OF HAWKINS COUNTY
CHURCH HILL, TENNESSEE**

GRAVELLY VALLEY ROAD WATER LINE EXTENSION

BID DATE: October 27, 2020
BID TIME: 2:00 P.M., Local Time
ADDENDUM DATE: October 23, 2020

This Addendum is issued to make certain additions, deletions, revisions, clarifications and/or alterations to the Contract Documents, Specifications, Drawings, and other requirements for the subject project. Each Bidder should acknowledge receipt of this Addendum on the Bid form; however, failure to do so does not relieve the Bidder from the requirements contained herein.

I. SPECIFICATIONS:

- A. **Section 33 12 23, Water Booster Station.** Page 33 12 23-2, Paragraph 2.1.B. Revise pump model from “3-stage” to “4-stage” and revise “7.5-HP” to “10-HP” in the second sentence. Delete “or approved equal” at the end of the same sentence.

END OF ADDENDUM

October 23, 2020 CTI ENGINEERS, INC.

/s/ David L. Jones, P.E.