

ADDENDUM ONE (1)

**LOUDON UTILITIES
LOUDON, TENNESSEE**

UPGRADE VONORE PUMP STATION

BID DATE: July 22, 2021
BID TIME: 2:00 P.M., Local Time
ADDENDUM DATE: July 7, 2021

This Addendum is issued to make certain additions, deletions, revisions, clarifications and/or alterations to the Contract Documents, Specifications, Drawings, and other requirements for the subject project. Each Bidder should acknowledge receipt of this Addendum on the Bid form; however, failure to do so does not relieve the Bidder from the requirements contained herein.

I. SPECIFICATIONS:

- A. **Section 33 14 43, Packaged Pumping System for Water Utilities.** On page 4, Paragraph 2.1.A, insert "Patterson Pump Company," before "or approved equal".
- B. **Section 33 14 43, Packaged Pumping System for Water Utilities.** On page 4, Paragraph 2.3.C, delete phrase "shall have a State Certification Label" in the last sentence.
- C. **Section 33 14 43, Packaged Pumping System for Water Utilities.** On page 14, Paragraph 2.21.D, replace the words "service pole" with the word "transformer" in the first sentence.

II. DRAWINGS:

- A. **Drawings M-101 and M-102, Booster Pump Station Schematic.** Add the following note to the end of the existing note, "Isolation valves (not shown) are to be provided for both the pressure relief valve and the flow meter discharge."

END OF ADDENDUM

July 7, 2021

CTI ENGINEERS, INC.
/s/ David L. Jones, P.E.