

## LETTER OF TRANSMITTAL

<b>TO:</b> J. Cumby Construction, Inc. W.O. Construction Co., Inc. Roy Joe Angel Construction Southern Constructors, Inc. Morgan Contracting, Inc. Haren Construction Co., Inc. Deltek, Inc. The Blue Book Dodge Data & Analytics Associated General Contractors Builders Exchange of Tennessee Construct Connect	Greg Shirley Brandy Garrett Vickie Frizzell Paula Snelling Norma George-Ferrara Cindy Osborne Patricia Manarin Erin McVeigh  Heather Lowery Rachael Taylor	<a href="mailto:gshirley@jcumbyconstruction.com">gshirley@jcumbyconstruction.com</a> <a href="mailto:bids@wocc.com">bids@wocc.com</a> <a href="mailto:patsy.angelbase@yahoo.com">patsy.angelbase@yahoo.com</a> <a href="mailto:psnelling@southernconstructorsinc.com">psnelling@southernconstructorsinc.com</a> <a href="mailto:normag@morgan1.com">normag@morgan1.com</a> <a href="mailto:cosborne@harenconstruction.com">cosborne@harenconstruction.com</a> <a href="mailto:publicrecords@deltek.com">publicrecords@deltek.com</a> <a href="mailto:emcveigh@mail.thebluebook.com">emcveigh@mail.thebluebook.com</a> <a href="mailto:dodge.bidding@construction.com">dodge.bidding@construction.com</a> <a href="mailto:planroom@agcetn.org">planroom@agcetn.org</a> <a href="mailto:heather@bxtn.org">heather@bxtn.org</a> <a href="mailto:rachael.taylor@constructconnect.com">rachael.taylor@constructconnect.com</a>
---	--	--

**FROM:** Jerry Hightower, P.E. Project Manager

**DATE:** September 23, 2022

**PROJ. NO.:** C20055

**SUBJECT:** Addendum No. 3  
 CFP Sodium Permanganate Conversion at Raw Water Intake  
 CU Project No. W2891X  
 Cleveland Utilities

**PAGES:** 1 pages follow

<p><b>PLEASE RESPOND</b></p> <p>→ → → →</p>	<p style="text-align: center;"><b>TO CONFIRM RECEIPT OF THIS ADDENDUM NO. 3 PLEASE SIGN AND EMAIL TO CTI</b></p> <p style="text-align: center;"><a href="mailto:vvisco@ctiengr.com">vvisco@ctiengr.com</a></p> <p><b>Company</b> _____</p> <p><b>Signature</b> _____</p> <p><b>Title</b> _____</p> <p><b>Date</b> _____</p>
---	---

**ADDENDUM NO. 3**

**CONTRACT DOCUMENTS AND SPECIFICATIONS  
FOR THE  
SODIUM PERMANGANATE CONVERSION AT CFP RAW WATER INTAKE  
CLEVELAND UTILITIES PROJECT NO. W2891X**

The following changes shall be made to the Contract Drawings:

**I. DRAWINGS**

- A.** On Drawing C-101.1 in the "Chain Link Fence and Gate Detail" REVISE the gate opening dimension to 8'-0" and the dimension of each half of the gate to 4'-0".
- B.** On Drawing C-101.1 in the lower left corner of the drawing ADD the following note applicable to the "Existing Valve" shown on the existing "20" Raw Water Pipeline (CIP)", upstream of the proposed flow meter and chemical feed point:

"Note: Cleveland Utilities has measured down from the existing ground level at this valve to the top of the valve operator nut and found this dimension to be 4.5 feet."

Date: September 23, 2022

CLEVELAND UTILITIES

/s/ Jon Sparkman, P.E.

Manager Water and Wastewater Division Engineering