

LETTER OF TRANSMITTAL

TO: Hurst Excavating, LLC
W.O. Construction Co., Inc.
Roy Joe Angel Construction
Southern Constructors, Inc.
Morgan Contracting, Inc.
J.S. Haren
Deltek, Inc.
The Blue Book
Dodge Data & Analytics
Associated General Contractors
Builders Exchange of Tennessee
Construct Connect

Amanda Flenniken amanda@hurstexc.com
Brandy Garrett bids@wocc.com
Vickie Frizzell patsy.angelbase@yahoo.com
Paula Snelling psnelling@southernconstructorsinc.com
Norma George-Ferrara normag@morgan1.com
bitting@jsharen.com
Patricia Manarin publicrecords@deltek.com
Erin McVeigh emcveigh@mail.thebluebook.com
dodge.bidding@construction.com
planroom@agcetn.org
Heather Lowery heather@bxtn.org
Rachael Taylor rachael.taylor@constructconnect.com

FROM: Don Tabor, P.E. Project Manager

DATE: September 26, 2022

PROJ. NO.: C22017

SUBJECT: Addendum No. 3
Wilkinson Road Pump Station
Cleveland Utilities

PAGES: 1 page follow

PLEASE RESPOND → → → →	TO CONFIRM RECEIPT OF THIS ADDENDUM NO. 3 PLEASE SIGN AND EMAIL TO CTI vvisco@ctiengr.com
	Company _____
	Signature _____
	Title _____
	Date _____

**ADDENDUM NO. 3
WILKINSON ROAD PUMP STATION
CLEVELAND UTILITIES
C.U. PROJECT NO.S2988X
CTI PROJECT NO. C22017**

I. CONTRACT DOCUMENTS AND SPECIFICATIONS

The following changes shall be made to the Specifications:

A. Section 33 32 19, “Submersible Sewage Pumps and Accessories”.

Part 2.2, Paragraph A.1, Page 33 32 19-3.

1. DELETE “1. Number of Units 3 each” and SUBSTITUTE therefor “1. Number of Units 2 each”.

B. Section 33 32 19, “Submersible Sewage Pumps and Accessories”.

Part 2.2, Paragraph C, Page 33 32 19-4.

1. DELETE Paragraph C in its entirety and SUBSTITUTE therefore the following:
“C. Provide two non-clog submersible sewage pumps. Both pumps shall be of the same design and capacity.”

Date: September 26, 2022

CTI Engineers, Inc.
/s/ Don Tabor, P.E.
Project Manager